

Navajo Tribal Utility Authority® An Enterprise of the Navajo Nation

2021 Annual Water Quality Report

Calendar Year 2021 Public Water System NN0403058 **Red Valley North**

NTUA'S Mission...

To provide safe and reliable affordable utility services that exceed our customers' expectation

General Information...

It is important for you, our valued customer, to understand the potential occurrence and presence of contaminants within your potable water. As water flows on or beneath the surface of the earth, it dissolves naturally occurring minerals and pollutants produced from animal and/ or human activity. These disturbed minerals and pollutants are called contaminants and could potentially be found in your potable water. Although, these contaminants may not necessarily pose a health risk to you, they may be of a particular risk to individuals with compromised immune systems. These individuals include persons diagnosed with cancer and undergoing chemotherapy, persons who have undergone organ transplants, persons with HIV/AIDS or other immune-deficiency disorders, and elderly and infants who may be prone to infection by these contaminants. These individuals should seek advice from their health care provider about consuming community potable water.

Where does my water come from?

Your water comes from two ground water sources.

How can I get involved? <

Feel free to contact the number provided below for more information or for a translated copy of the report if you need it in another language.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

For more information

Contact: Raquel Whitehorse, Supervisor, Navajo Tribal Utility Authority, PO Box 170, Fort Defiance, AZ 86504-0170 Phone: (928) 729-6239 or Fax: (928) 729-6249.

Saving Water at Home

- Turn off the faucet while brushing your teeth. Take shorter showers.
- Fix leaks in faucets, showerheads and toilets.
- Washing full loads of dishes and laundry
- Buying water saving devices like high-efficiency appliances

This report is a snapshot of your water quality.

This report is a snapshot of your water quality. Included are details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. We are committed to providing you with information because informed customers are our best allies.

Consumer Confidence Report 2021

The Navajo Tribal Utility Authority (NTUA) operates and maintains the public water system within your community. NTUA has created the Consumer Confidence Report to reassure our dedication and commitment in providing safe and quality potable water to you, our valued customer. Please take a few minutes to view this report and become familiar with your potable water.

The Consumer Confidence Report will provide valuable information about your potable water, such as, the type of water source, recent water quality detections, potential health effects, and governing drinking water standards and regulations. With water being an intricate part of our lifestyle, NTUA will continue to ensure the protection and quality of potable water served to your

Your Water Source... \sim

NTUA provides potable water from several different sources. The majority of communities receive their potable water from ground water. Ground water is pumped from wells, ranging from several feet to hundreds of feet in depth, and treated to become potable water. Some communities receive their potable water from streams and springs. Stream and spring water is treated, as if it were ground water, to become potable water. However, some communities receive their potable water from surface water, such as, the Animas River, the San Juan River, Farmington Lake, and Lake Powell. Surface water is pre-treated, filtered, and post-treated to become potable water.

Safe Drinking Water Act...

In 1996, the Safe Drinking Water Act (SDWA) was amended to ensure public water systems provide safe drinking water to the public and meet drinking water quality standards. The United States Environmental Protection Agency (USEPA) is governed to oversee states, localities, and water suppliers who implement these drinking water standards. Pursuant to SDWA, USEPA established maximum contaminant levels, maximum contaminant level goals, action levels, and treatment techniques to protect public health from drinking water contamination. NTUA is also regulated by the Navajo Nation Environmental Protection Agency (NNEPA) and must also comply with Navajo Nation Primary Drinking Water Regulations (NNPDWR).

NOTE: Drinking water, including bottled water, may reasonably be expected to contain minimal concentrations of some contaminants. The presence of contaminants does not necessarily indicate the drinking water poses a health risk. Information about contaminants and potential health effects can be obtained from the USEPA Safe Drinking Water Hotline (1-800-426-4791) or online at http://www.epa.gov/safewater.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. The Environmental Protection Agency (EPA) and Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity including: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil & gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally-occurring or be the result of oil & gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Water Quality Table - NN3503028 - Red Valley North

The table below lists all of the drinking water contaminants detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires monitoring for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

MRDI G	MRDI	Your Water			Sample Date	MRDL Exceeded	Typical Source	
		770.01			Dato		Typical States	
4	4	0.7517	0.52	1.1	2021	No	Drinking water additive used for disinfection	
al, ppm							·	
MCLG	MCL	Your Water	Ra Low	nge Hiah	Sample Date	Violation	Typical Source	
							7,	
N/A Jnits: ppb	80	2.7	N/A	N/A	2021	No	By-product of drinking water chlorination	
NTAMI	NAN'	TS						
2	2	0.356	0.24	0.356	2020	No	Discharge of oil drilling wastes and from metal refineries; erosion of natural deposits	
4	4	0.12	0.11	0.12	2020	No	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories	
		126	83.7	126	2020	N/A	Erosion of natural deposits; salt water intrusion	
CONT	<u>AMIN</u>	NANTS	<u> </u>					
0 Iranium) l	15 Jnits: p	3 Ci/L	1.2	3	2020	No	Erosion of natural deposits	
0 s: pCi/L	5	1.4	1.3	1.4	2020	No	Erosion of natural deposits	
MCLG	Action Level	Your Water	Ran	ge	Sample Date	A.L. Exceeded	Typical Source	
PER R	ULE			2				
1.3	1.3	0.031	31 0 sites over		2020	No	Corrosion of household plumbing systems; erosion of	
			Action Level				natural deposits; leaching from wood preservatives	
-	15	1.5			2021	No	Corrosion of household water plumbing systems; discharges	
			Action	Level			from industrial manufacturesrs; erosion of natural deposits	
	4 al, ppm MCLG BY-PRO N/A Jnits: ppb NTAMI 2 4 CONT 0 Iranium) 0 s: pCi/L MCLG PER RI	4 4 al, ppm MCLG MCL BY-PRODUC N/A 80 Jnits: ppb NTAMINAN 2 2 4 4 CONTAMIN 0 15 Iranium) Units: p 0 5 s: pCi/L MCLG Action Level PER RULE 1.3 1.3 centile 0 15 entile	## A	MRDLG MRDL Water Low 4	MRDLG MRDL Water Low High 4	MRDLG MRDL Water Low High Date 4 4 0.7517 0.52 1.1 2021 al, ppm MCL Your Water Low Range Low Sample Date BY-PRODUCTS N/A 80 2.7 N/A N/A 2021 Jnits: ppb NTAMINANTS 2 2 0.356 0.24 0.356 2020 4 4 0.12 0.11 0.12 2020 LCONTAMINANTS 0 15 3 1.2 3 2020 Low 16 4 1.3 1.4 2020 16 2 1.4 1.3 1.4 2020 17 2	MRDLG MRDL Water Low High Date Exceeded 4 4 0.7517 0.52 1.1 2021 No all, ppm MCLG MCL Your Water Range Low Sample Date Violation BY-PRODUCTS N/A N/A N/A 2021 No NTAMINANTS 2 2 0.356 0.24 0.356 2020 No 4 4 0.12 0.11 0.12 2020 No **CONTAMINANTS 0 15 3 1.2 3 2020 No **CONTAMINANTS 0 15 3 1.2 3 2020 No **CONTAMINANTS 0 15 3 1.2 3 2020 No **CONTAMINANTS 0 5 1.4 1.3 1.4 2020 No **GRADIANTS 0 5 1.4 1.3 1.4 2020 No	

Definitions: ppm -parts per million, or milligrams per liter (mg/L); ppb -parts per billion, or microgram per liter (ug/L); positives samples -the number of positive samples taken that year; % positive samples/month -percent of samples taken monthly that were positive; pCi/L -picocuries per liter; ND -Not detected; N/A -Not applicable; MCLG -Maximum Contaminant Level Goal is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.; MCL -Maximum Contaminant Level is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.; MRDL -Maximum Residual Disinfectant Level; MRDLG -Maximum Residual Disinfectant Level Goal; TT -Treatment Technique is a required process intended to reduce the level of a contaminant in drinking water.; AL -Action Level is the concentration of copper and lead in potable water which determines if treatment requirements are necessary for a public water system.; 90th Percentile -Statistical value used to determine if Action Level is exceeded and is determined by calculating the value at which 90% of the samples tested were below that value.

Special Education Statements - Additional Information for Lead.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. PWS system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at 1-800-426-4791 or at http://www.epa.gov/your-drinking-water/basic-information-about-lead-drinking-water.

Microbiological Testing

We are required to test your water regularly for signs of microbial contamination. Positive test results could lead to follow-up

Sampling	Sampling	Total E. Coli	Assessment	Assessments
Requirements	Conducted (months)	Positive	Triggers	Conducted
1 Samples due monthly	12 out of 12	0	0	0

investigations called assessments and potentially the issuance of public health advisories. Assessments could lead to required corrective actions. The following information summarizes the results of those tests.