

## Public Notice for Monitoring/Reporting and Other Violations

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the period covered by this report, we did not complete all monitoring or testing for the contaminants listed below, and therefore cannot be sure of the quality of your drinking water during that time. Violations which have not been returned to compliance will be repeated annually. The table below lists the contaminants we did not properly test for or other violations during the report period.

Contaminant Name	Type of Violation	Begin/End Date	Steps Taken to Correct the Violation	Return to Compliance	Return Date	Action Comment
Arsenic	Major monitoring/reporting violation for routine chemical monitoring.	01/01/2022 - 03/31/2022	Reporting monitoring results as required.	Yes	05/19/2022	2022-1Q. Arsenic M/R. RTC. Full Sample set collected 05/19/2022.

**What should I do, as a consumer?** There is nothing you need to do at this time.

**What is being done by the utility?** We will work with our regulatory official to conduct all required contaminant monitoring as directed.

### City of Farmington - Surface Water Source

Substance	MCL	MCLG	Our Water	Range of Detection	Sample Date	Violation (Y or N)	Typical Source of Contamination
<b>Microbiological Contaminants</b>							
Turbidity (NTU)	0.3	NA	0.5 (Highest Single Measurement)	NA	Jan-Dec 2022	N	Soil runoff
99.94% of the samples were below the TT value of 0.3 NTU. A value less than 95% constitutes a TT violation. Any measurement in excess of 1 NTU is a violation unless otherwise approved by the state. Turbidity is a measure of the cloudiness of the water. We monitor turbidity because it is a good indicator of the effectiveness of our filtration system.							
<b>Radioactive Contaminants</b>							
Alpha emitters (pCi/L)	15	0	1.1	0.1-1.1	8/15/2017	N	Erosion of natural deposits
Beta/photon emitters (pCi/L)	0	50	2.5	2.0 - 2.5	8/15/2017	N	Decay of natural and man-made deposits. The EPA considers 50 pCi/L to be the level of concern for Beta particles.
Combined Radium (pCi/L)	5	0	0.38	0.27 - 0.38	8/15/2017	N	Erosion of natural deposits
Uranium (ppb)	30	0	1	ND - 1	8/15/2017	N	Erosion of natural deposits
<b>Disinfectants and Disinfection Byproducts, Stage 2</b>							
Substance	MCL	MCLG	LRAA	Range of Detection	Sample Date	Violation (Y or N)	Typical Source of Contamination
TTHMs [Total Trihalomethanes] (ppb)	80	N/A	79	34.2 - 107.0*	Jan-Dec 2022	N	By-product of drinking water chlorination
HAA5 [Five Haloacetic Acids] (ppb)	60	N/A	28	13.9 - 29.8	Jan-Dec 2022	N	By-product of drinking water chlorination
*One TTHM sample site in 2022 had a result of 91.3 ppb and 107.0 ppb. However, the system did not incur an MCL violation as the locational running annual average (LRAA) result for that site was below the MCL of 80 ppb.							
Substance	MRDL	MRDLG	Our Water	Range of Detection	Sample Date	Violation (Y or N)	Typical Source of Contamination
Chlorine (ppm)	4	4	1.1 (RAA)	ND - 1.68	Jan-Dec 2022	N	Disinfection of water
<b>Inorganic Contaminants</b>							
Substance	MCL	MCLG	Level Detected	Range of Detection	Sample Date	Violation (Y or N)	Typical Source of Contamination
Fluoride (ppm)	4	4	0.67	0.61 - 0.67	7/12/2022	N	Erosion of natural deposits; water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Barium (ppm)	2	2	0.085	0.084 - 0.085	7/12/2022	N	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Selenium (ppb)	50	50	1.1	1.0 - 1.1	7/12/2022	N	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Sodium (ppm)	N/A	N/A	27	26 - 27	7/12/2022	N	Erosion of natural deposits
Copper & Lead	Action Level	MCLG	Our Water	Number of sites exceeding AL	Sample Date	Violation	Typical Source of Contamination
Copper (ppm)	1.3 (AL)	1.3	0.3	0	July - August 2020	N	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Lead (ppb)	15 (AL)	0	4	0	July - August 2020	N	Corrosion of household plumbing systems; Erosion of natural deposits



# Navajo Tribal Utility Authority

An Enterprise of the Navajo Nation

## 2022 Annual Water Quality Report

### Sweetwater

Calendar Year 2022 - Public Water System ID#: 0400399

This report is a snapshot of your water quality. Included are details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. We are committed to providing you with information because informed customers are our best allies.

### NTUA's Mission...

To provide safe, reliable and affordable utility services that exceed our customers' expectations.

### Safe Drinking Water Act...

In 1996, the Safe Drinking Water Act (SDWA) was amended to ensure public water systems provide safe drinking water to the public and meet drinking water quality standards. The United States Environmental Protection Agency (USEPA) is governed to oversee states, localities, and water suppliers who implement these drinking water standards. Pursuant to SDWA, USEPA established maximum contaminant levels, maximum contaminant level goals, action levels, and treatment techniques to protect public health from drinking water contamination. NTUA is also regulated by the Navajo Nation Environmental Protection Agency (NNEPA) and must also comply with Navajo Nation Primary Drinking Water Regulations (NNPDWR).

*NOTE: Drinking water, including bottled water, may reasonably be expected to contain minimal concentrations of some contaminants. The presence of contaminants does not necessarily indicate the drinking water poses a health risk. Information about contaminants and potential health effects can be obtained from the USEPA Safe Drinking Water Hotline (1-800-426-4791) or online at <http://www.epa.gov/safewater>.*

### For more information please contact . . .

Raquel Whitehorse, Supervisor,  
P.O. Box 170, Fort Defiance, AZ  
86504-0170  
phone (928) 729-6239,  
fax 928-729-6249.

### Consumer Confidence Report 2022

The Navajo Tribal Utility Authority (NTUA) operates and maintains the public water system within your community. NTUA has created the Consumer Confidence Report to reassure our dedication and commitment in providing safe and quality potable water to you, our valued customer. Please take a few minutes to view this report and become familiar with your potable water.

The Consumer Confidence Report will provide valuable information about your potable water, such as, the type of water source, recent water quality detections, potential health effects, and governing drinking water standards and regulations. With water being an intricate part of our lifestyle, NTUA will continue to ensure the protection and quality of potable water served to your community.

### Your Water Source...

NTUA provides potable water from several different sources. The majority of communities receive their potable water from ground water. Ground water is pumped from wells, ranging from several feet to hundreds of feet in depth, and treated to become potable water. Some communities receive their potable water from streams and springs. Stream and spring water is treated, as if it were ground water, to become potable water. However, some communities receive their potable water from surface water, such as, the Animas River, the San Juan River, Farmington Lake, and Lake Powell. Surface water is pre-treated, filtered, and post-treated to become potable water.

### General Information...

It is important for you, our valued customer, to understand the potential occurrence and presence of contaminants within your potable water. As water flows on or beneath the surface of the earth, it dissolves naturally occurring minerals and pollutants produced from animal and/or human activity. These disturbed minerals and pollutants are called contaminants and could potentially be found in your potable water. Although, these contaminants may not necessarily pose a health risk to you, they may be of a particular risk to individuals with compromised immune systems. These individuals include persons diagnosed with cancer and undergoing chemotherapy, persons who have undergone organ transplants, persons with HIV/AIDS or other immune-deficiency disorders, and elderly and infants who may be prone to infection by these contaminants. These individuals should seek advice from their health care provider about consuming community potable water.

### Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. The Environmental Protection Agency (EPA) and Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

## Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity including:

microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil & gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally-occurring or be the result of oil & gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

## How can I get involved?

Please feel free to contact us at 928-729-6239 or on NTUA's web site [www.ntua.com](http://www.ntua.com) for more information. \*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.\*

### Tips to help Conserve Water at Home

- Turn off the faucet while brushing your teeth.
- Take shorter showers.
- Fix leaks in faucets, showerheads and toilets.
- Washing full loads of dishes and laundry.
- Buy water saving devices and appliances.

## Definitions

### Term Definition

<b>ppb</b>	parts per billion, or microgram per liter (ug/L)
<b>positives samples</b>	the number of positive samples taken that year
<b>% positive samples/month</b>	percent of samples taken monthly that were positive
<b>ND</b>	Not detected
<b>N/A</b>	Not applicable
<b>MCLG</b>	Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
<b>MCL</b>	Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
<b>MRDL</b>	Maximum Residual Disinfectant Level
<b>MRDLG</b>	Maximum Residual Disinfectant Level Goal
<b>TT</b>	Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
<b>AL</b>	Action Level: The concentration of copper and lead in potable water which determines if treatment requirements are necessary for a public water system.
<b>90th Percentile</b>	Statistical value used to determine if Action Level is exceeded. Determined by calculating the value at which 90% of the samples tested were below that value.

## Table Definitions...

**Action Level (AL):** The concentration of copper and lead in potable water which determines if treatment requirements are necessary for a public water system.

**Maximum Contaminant Level (MCL):** The maximum permissible level of a contaminant in potable water which is delivered to any user of a public water system.

**Maximum Contaminant Level Goal (MCLG):** The maximum level of a contaminant in potable water at which no known or anticipated adverse health effect would occur, allowing for an adequate margin of safety.

**Maximum Residual Disinfectant Level (MRDL):** The maximum permissible level of a disinfectant in potable water which is delivered to any user of a public water system.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The maximum level of a disinfectant in potable water at which no known or anticipated adverse health effect would occur, allowing for an adequate margin of safety.

**Treatment Technique (TT):** A required physical or chemical treatment process intended to reduce the level of a contaminant in potable water.

**Locational Running Annual Average (LRAA):** the arithmetic average of analytical results for samples taken at a specific monitoring location during the previous four calendar quarters.

## Where does my water come from?

Your water comes from 2 ground water sources and 1 surface water source.

## Water Quality Table

The table below lists all of the drinking water contaminants detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires monitoring for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Sweetwater - Public Water System #NN0400399									
Contaminants	MRDLG	MRDL	Your Water	Range Low	Range High	Sample Date	MRDL Exceeded	Typical Source	
<b>DISINFECTANTS</b>									
Chlorine Units: Chlorine residual, ppm	4	4	0.5738	0.1	1.59	2022	No	Drinking water additive used for disinfection	
Contaminants	MCLG	MCL	Your Water	Range Low	Range High	Sample Date	Violation	Typical Source	
<b>DISINFECTION BY-PRODUCTS</b>									
Five Haloacetic Acids (HAA5) Units: ppb	N/A	60	21.9	ND	48	2022	No	By-product of drinking water chlorination	
Total Trihalomethanes (TTHMs) Units: ppb	N/A	80	63.4	16.4	81.9	2022	No	By-product of drinking water chlorination	
<b>INORGANIC CONTAMINANTS</b>									
Arsenic Units: ppb	0	10	8.7	7	9.3	2022	No	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes	
Fluoride Units: ppm	4	4	0.55	N/A	N/A	2018	No	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories	
Sodium Units: ppm	N/A	N/A	130	120	130	2021	No	Erosion of natural deposits; salt water intrusion	
<b>RADIOLOGICAL CONTAMINANTS</b>									
Adjusted Alpha (Excl. Radon & U) Units: pCi/L	0	15	0.4	0.1	0.4	2021	No	Erosion of natural deposits	
Uranium (combined) Units: ppb	0	30	29.6	4.5	29.6	2021	No	Erosion of natural deposits; water additive which promotes	
Contaminants	MCLG	Action Level	Water	Range	Sample Date	A.L. Exceeded	Typical Source		
<b>LEAD AND COPPER RULE</b>									
Copper - 90th Percentile, Units: ppm	1.3	1.3	0.14	0 sites over Action Level	2021	No	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives		

## Special Education Statements

### •Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. This public water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at [www.epa.gov/safewater/lead](http://www.epa.gov/safewater/lead).

### •Additional Information for Arsenic

While your drinking water meets the EPA standard for arsenic, it does contain low levels of arsenic. The EPA standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. The EPA continues to research the health effects of low levels of arsenic which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.